

6 The Cedar Business Centre Avon Road, Cannock, Staffs WS11 1QJ Tel: +44 (0)1543 501 600 Fax: +44 (0)1543 501 601

Manufacturer's Declaration of Conformity

We declare that the following products:-

AEM10002, AEM10002/DS, AEM10004, AEM10004/DS, AEM10002T, AEM10004T Monitored Mini Face to Face Fixed Electro-magnetic Locks

have been successfully tested to the following:-

Evidence of Fire Test Compliance

- Fire Tested Report 417165 dated 23rd August 2019 to EN1634-1 on Timber Doors for 30 and 60 mins. on both exposed and unexposed sides of the door.
 - Exova Warrington Fire Test Assessment Report No.432748 dated 27th October 2020
 - 1mm thick intumescent sleeve around the studs within the door leaf to comply with EN1634-1
- Doorset A 44mm thick Door leaf comprised of a particleboard core with 6mm hardwood lipping to the vertical edges. The leaf was mounted in a softwood frame – Density 640 kg/m³
- Doorset B 54mm thick Door leaf comprised of a particleboard core with 6mm hardwood lipping to the vertical edges. The leaf was mounted in a hardwood frame – Density 640 kg/m³

Evidence of Performance Test

- Certified and tested to TS010:2016 WTE Report No. 16-030 Dated 25th January 2017
- Classification Code

3 7 B 1 3 2 2 A

- Durability Grade 7 (200,000 cycles)
- Holding force without Z&L Bracket
 - Grade 2 (Tested Holding Force 2090N / 470lbf / 213kgf)
- Salt Spray Tested Grade 3 (96 hours)
- Safety Grade 1 (Safety Bolts)
- Type of Device Grade A (Face to face fixed Electro-Magnetic Lock)

EMC Directive 89 / 336 / EEC

- Tested by Matrix Test Laboratory, 2F, No. 146 Jian Yi Road, Chung-Ho Dist., New Taipei City, Taiwan R.O.C.
- Certification No. R12041303E-B01 dated 18th April 2012
- EN61000-6-3:2007 + A1:2011 (Emissions)
- EN61000-6-1:2007 (Immunity) IEC61000-4-2:2008, IEC61000-4-3:2006+A1:2007+A2:2010 IEC61000-4-8:2009

Ko'lall

Technical Director Signed on behalf of Securefast plc

Date : 25th January 2021