

Manufacturer's Declaration of Conformance

We declare that the following product:-

**AML-350M-PL-12 and AML-350-PL-24
Electric Lock with Preload**

has been successfully tested

Fire Test Report


- Report No. BMT/FEP/F14080 AR1 dated 19th May 2014 – Tested by Chiltern International Fire Ltd for 30min and 60 min Single Action Timber Doors

Fire Tested – FD30

- Lock fitted in the frame head with keep fitted appropriate to the latch in the leaf head 200mm from the closing edge.
- Door – 44mm thick Halspan – Density 630 – 635 kg/m³
- 1mm thick Interdens intumescent fitted around latch keep, latch body and behind forend

Fire Tested – FD60

- Lock fitted in the frame head with keep fitted appropriate to the latch in the leaf head 200mm from the closing edge.
- Door – 54mm thick Halspan – Density 630 – 635 kg/m³
- 1mm thick Interdens intumescent fitted around latch keep, latch body and behind forend



Technical Director
Signed on behalf of Securefast plc

Date : 24th January 2022